

DESCRIPTION

This product is a scale and corrosion inhibitor for hot water boiler recirculating systems and chilled water recirculating systems. It is a borate/nitrite formula for superior scale and corrosion inhibition, with easy testing and control.

DIRECTIONS

The dosage of will depend on the amount of water contained in the recirculating system.

Normal treatment dosage is 1 gallon for every 125 gallons of water contained within the system. This product may be injected directly into the recirculating system through the use of a regular bypass feeder. Mild steel piping and feeding equipment may be used. Control the level of product by maintaining a nitrite (NO_2) level of between 350 – 1000 ppm.

In chilled water recirculating systems, a microbicide is recommended as a preventative treatment or for control if infestation occurs. Many hot water and chilled water recirculating systems may require the use of an oxygen scavenger product. Control the oxygen scavenger product feed rates by maintaining a sulfite (SO_3) level of between 20 – 40 ppm.

LOOP TREAT NITRO

BORATE / NITRITE SCALE
AND CORROSION INHIBITOR

FOR USE IN BOTH
HOT OR COLD
WATER CLOSED LOOPS

WARNING:

Harmful if swallowed.
May cause severe burns.

See back panel for further precautions
and first aid instructions.

KEEP OUT OF REACH OF CHILDREN

Sold By:

WARNING:

Harmful if swallowed. May cause severe burns. Do not take internally. Avoid contact with skin, eyes and mucous membranes.

FIRST AID:

If Swallowed: Give person several glasses of water. Do NOT induce vomiting. Obtain immediate medical assistance.

If In Eyes: Flush with plenty of cool water for at least 15 minutes. Obtain immediate medical assistance.

If On Skin: Wash thoroughly with soap and water. If irritation persists, obtain medical assistance.

KEEP OUT OF REACH OF CHILDREN

This Product Contains	CAS Number
Water7732-18-5
Sodium Hydroxide1310-73-2
Sodium Nitrite7632-00-0
Sodium Borate1303-96-4
Anionic DispersantNo CAS Number

198392809

NET CONTENTS:

5 6 20 30 35 55
GALLONS